

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC24107451477

Valid from: Nov.12,2024

Valid until: Nov.11,2034

NAME AND REGISTERED ADDRESS OF THE APPLICANT Guangdong Guard Group Co., Ltd
No. 1, industrial transfer park industrial park, lelang road, lechang city

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Guangdong Guard Group Co., Ltd
No. 1, industrial transfer park industrial park, lelang road, lechang city

NAME AND LOCATION OF THE FACTORY Guangdong Guard Group Co., Ltd
No.1, Industrial Transfer Industrial Park, Lelang Road, Lechang City

PRODUCT NAME, MODEL AND SPECIFICATION Low-voltage Switchgear Assemblies
GP-H-X 主母线:InA=1000A~400A,Icw=30kA;Un=400V,Ui=690V;50Hz;户内型;IP21;IK10;具有遥测、遥信功能;周围空气日均温度最大值:55℃

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 7251.2-2023;GB/T 7251.8-2020

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

郑士泉

SIGNATURE

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666
<http://www.cqc.com.cn>